

Type Approval Certificate

Certificate No: **STAS/26/052/DM149/01**

Date: **28 July 2026**

A	Certificate Holder:
	CALA Homes Ltd Adam House, 5 Mid New Cutlins, Edinburgh EH11 4DU E-mail: SKelso@Cala.co.uk

Tel: 0131 453 0072

B	Type Titles:
	Description: ALLAN END TERRACE 1 2026

C	The type approval has been assessed on the following drawings and specifications:
	See attached annexe to this certificate

D	Climatic conditions: The design may be built in areas where the climatic conditions are equal to or less than those detailed below:		
	Wind: (as defined in BS 6399-2)	Standard effective wind speed, V_e = For maximum effective height = Has funnelling been considered?	24.5m/s 10m to ridge No
	Wind: (as defined in CP3: Chapter V)	Design wind speed, V_s = (relevant to the building frame, at a height of 3m or less)	27.56m/s
	Snow: (as defined in BS 6399-3)	Site snow load, S_o = Influenced by adjacent buildings?	0.75 kN/m²
	Resistance to moisture/durability of exposed elements:	Max exposure (to wind driven rain) grading, as defined in BRE Report – Thermal Insulation: Avoiding Risks, Second Edition, 1994, to be exposure zone: Exposure to sea spray (i.e. coastal region) or de-icing salts? Other air contaminants or biological factors – please specify any enhanced resistance if applicable (refer to BS7543 for guidance)	Exposure Zone 3 No
	Design Life: (per BS 7543 – Durability of buildings and building elements, products and components)	Category of building design life = Design life of primary building envelope	60 years 60 years

E	Conditions of certification:
	- The design shown and the specifications and materials referred to have been assessed and approved in accordance with the Building (Scotland) Regulations 2004 and in accordance with the supporting guidance in the Domestic Technical Handbooks which came into force with effect from 6th April 2026. - The certificate shall be valid until invalidated by formal notice by the Scottish Building Standards Hub. - The design shown and the materials specified shall not be changed without reference to the Scottish Building Standards Hub who are responsible for certifying the system. - Where reference is made on a plan or specification document to any Code of Practice, British or European Standard or manufacturer's instruction it shall be construed as a reference to such publication in the form in which it is in force at the date of this certificate. - This certificate should not be regarded as a formal approval under the building warrant process prescribed by the Building (Scotland) Act 2003 enacted from 1 May 2005. - The Harley Haddow Consulting Engineers Statement of Structural Adequacy referenced here under Section G dated 28th May 2026, confirm that a structural appraisal has been carried out. It confirms that further site-specific information MUST BE made available when a site-specific building warrant is sought. Such additional information should take cognisance of Procedural Guidance on Certification including information to be submitted with a Building Warrant Application dated April 2010 Version 2 (January 2017). Confirmation of a holistic approach to structural adequacy of the <u>entire completed building</u> shall be provided by a registered engineer to the local authority within whose area the site-specific dwelling is to be built. - Mandatory Standard 4.14 - The applicant will provide a connectivity plan, showing details of proposed connections & network, to the verifier for each site.

9. This certificate confirms compliance with Mandatory Standard 3.28. This is based on actual 'worst case' criteria outlined within CIBSE TM59 'Design methodology for the assessment of overheating risk in homes' (2017). On this basis, further site-specific information is not necessary
10. Site specific information will be required prior to completion to confirm the actual TDER and DDER for the STAS approved house type on each plot on a particular site.
11. Site specific elements, such as those for access, ground conditions, drainage, EV charging, broadband connection, suppression system drawings (where required) etc, require to be assessed by the verifier.
12. This certificate should be read with the related certificate STAS/26/052/DM149/SS, STAS/26/052/DM149/SD, and STAS/26/052/DM149/UCR.

F	Document Number	Revision	Description
	CALA Plans:		
	ALN-WD1-ET1	I	GENERAL ARRANGEMENT - PLANS AND ELEVATIONS (DMEV)
	ALN-WD1-ET1	I	GENERAL ARRANGEMENT - PLANS AND ELEVATIONS (MVHR)
	ALN-WD2-ET1	D	UNDERBUILD LAYOUTS
	ALN-WD6	-	STAIR DETAILS - PLANS & SECTIONS
	ALN-WD9.1-ET1	D	ELEVATIONAL TREATMENT 1 - BASE COURSE STONE (DMEV)
	ALN-WD9.1-ET1	D	ELEVATIONAL TREATMENT 1 - BASE COURSE STONE (MVHR)
	Harley Haddow Plans:		
	310857-HAH-(ALL-ET1)-DR-S-00100	I01	FOUNDATION & SUSPENDED SLAB LAYOUT
	310857-HAH-(ALL-ET1)-DR-S-00110	I01	FOUNDATION SECTIONS
	310857-HAH-(ALL-ET1)-DR-S-00120	B08	GROUND & FIRST FLOOR LAYOUT
	310857-HAH-(ALL-ET1)-DR-S-00130	I02	ROOF LAYOUT
	310857-HAH-XX-XX-DR-S-00300	I01	TIMBER FRAME CONSTRUCTION DETAILS
	310857-HAH-XX-XX-DR-S-00301	I01	EXTERNAL MASONRY LEAF DETAILS
	CAS 15100_02	M	GROUND AND FIRST FLOOR MVHR DESIGNS
	CAS 15363_02	-	GROUND AND FIRST FLOOR DMEV DESIGNS
	51094925-285634-ALLAN-ET1-ZZ-DR-H-04	1	GROUND AND FIRST FLOOR DMEV DESIGNS
	A23465-1	E	ABOVE GROUND DRAINAGE ISOMETRIC
	NC Designs:		
	13524/M2-1	J	GROUND FLOOR SPACE HEATING DESIGNS (ASHP)
	13524/M2-2	J	FIRST FLOOR SPACE HEATING DESIGNS (ASHP)
	13524/M2-6	J	GROUND FLOOR DHW DESIGNS (ASHP)
	13524/M2-7	J	FIRST FLOOR DHW DESIGNS (ASHP)
	13524/M2-5	K	EQUIPMENT SCHEDULE (IDEAL)

G	Certification
	CALA Homes Light and Space House Type Range Harley Haddow Statement of Structural Adequacy Reference: 310857 Rev C - Dated 28th May 2026

H	Specification	
	Cala Documents:	
	Compliance_2026 ALLAN_Allan ET1 (2023 Regs) - ASHP_2026 (DMEV)	SAP/ENERGY COMPLIANCE REPORT (AIR SOURCE HEAT PUMP)
	Compliance_2026 ALLAN_Allan ET1 (2023 Regs) - ASHP_2026 (MVHR)	SAP/ENERGY COMPLIANCE REPORT (AIR SOURCE HEAT PUMP)
	Standard Supporting Documents:	
	Refer to STAS/26/052/DM149/SD	Standard Details
	Refer to STAS/26/052/DM149/SS	Standard Specifications
	Refer to STAS/26/052/DM149/UCR	U-values and Condensation Risk
	FES Group Overheating Assessments	Compliance Reports
I	Authority:	
	This system type approval certificate consisting of 3 pages is authorised by the Scottish Building Standards Hub on behalf of the Local Authority Building Standards Scotland (LABSS).	